



PRODUCT LISTING SCHEME

Certificate Number : STL-COC-Z0082
Issue No : 01

This Certificate is awarded to the following product(s) which has / have complied with the requirements of the listed standard(s).

Applicant : **Liang Chew Hardware Pte Ltd**
 133 Kitchener Road
 Singapore 208517

Product : Medical Gas Copper Tube

Brand / Model : KEMBLA / PIPCMG-K

Detail : Diameter (mm): 15 to 28 - Half Hard Temper
 Diameter (mm): 35 to 108 - Hard Drawn

Test Standard(s) : BS EN 13348: 2016,
 AS/NZS 4020: 2018 Appendix H


Product conformity Certificates are awarded on the basis of an assessment of the following type-test report(s):

2322316/02-OYC, 2322316/03-CPC

Date of Original Issue : 10 June 2026

Date of Last Revision : NA

Date of Expiry : 09 June 2028



Head, Certification
Singapore Test Lab Pte Ltd

Page 1 of 1

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of Singapore Test Lab Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to the Terms and Conditions of Singapore Test Lab Pte Ltd. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested.



Singapore Test Lab Pte Ltd certifies according to ISO / IEC 17065

